



PUNJAB STATE TRANSMISSION
CORPORATION LIMITED

PUNJAB STATE TRANSMISSION CORPORATION LIMITED

Regd. Office: - Shakti Sadan, The Mall, Patiala - 147001, Punjab, India.

O/o SE/Planning, PSTCL, Patiala.

Fax/Ph: - 0175-2205502, Email: - se-planning@pstcl.org

CIN - U40109PB2010SGC033814

Amendment No. 11 /2022-23

To

1. Dy. CE/Grid Construction, PSTCL, Ludhiana.
2. Dy. CE/TS (D), PSTCL, Patiala.
3. Dy. CE/Civil Works, PSTCL, Patiala.
4. SE/TLSC, PSTCL, Patiala.


Memo No. 249/52/P1- / Dated:- 27 -05-2022.


Subject:- Augmentation of 1 No. 220/66kV, 100MVA Transformer with 1 No. 220/66 kV, 160 MVA transformer at 220 kV Substation Amloh.

The scope of the work is planned as follows.

Sr. No.	Name of scope	Scope of Work	Estimated Cost of work (Rs. Cr.)	Remarks
1.	220kV Substation Amloh	Augmentation of 1No. 100MVA, 220/66 kV T/F with 160 MVA, 220/66 kV at 220 kV substation Amloh	9.5273	<ol style="list-style-type: none">1. The work has been planned in line with the approval of Director/Tech, PSTCL and in view of emergency condition of higher loading of transformers installed at 220 kV substation Amloh.2. This amendment is subject to the ex post-facto approval of committee of Directors (Director/Tech. & Independent Director) and ratification by BODs.3. Estimated cost has been considered as per cost data 2021-22 furnished by O/o TS Design.4. This work shall be included in the transmission works for the FY 2022-23.5. Total estimated cost after including EC@15% and IDC@10.37% shall be approx. Rs. 12.0926 Cr.

This issues with the approval of Director/Tech.


SE/Planning,
PSTCL, Patiala.


26/5/2022

253/58
CC:- 27.05.2022

1. Director/Technical, PSTCL, Patiala.
2. CE/TS, PSTCL, Patiala.
3. CE/P&M, PSTCL, Ludhiana.
4. CE/Planning, PSPCL, Patiala.
5. Dy. CE/P&M Circle, PSTCL, Ludhiana.
6. SE/Civil Design, PSTCL, Patiala.