



**PUNJAB STATE TRANSMISSION CORPORATION LIMITED**

Regd. Office:- PSEB Head Office, The Mall, Patiala – 147001, Punjab, India

O/o SE/Planning & Communication, PSTCL, Patiala

Fax/Ph:- 0175-2205502, Email:- [se-planning@pstcl.org](mailto:se-planning@pstcl.org)

CIN-U40109PB2010SGCO33814

To

Amendment No: 15/2020-21

- 1) Dy. CE/Grid Construction, PSTCL, Ludhiana.
- 2) Dy. CE/TS (Design), PSTCL, Patiala.
- 3) Dy. CE/Civil Works, PSTCL, Patiala.

Memo No. 1713/15

/P-II/ 70A

Dated: 09/9/2020

**Subject: Amendment in the Sr. No. 66 of MYT 2017-20.**

It has been decided to amend the following Transmission work in the MYT 2017-20:-

Sr. No.	Existing			New			Remarks
	Name of S/stn.	Existing Scope of Work in MYT 2017-20	Est. Cost (in Lacs)	Name of S/stn.	Amended Scope of Work	Est. Cost in Lacs)	
Sr. No. 66 of MYT 2017-20	132 kV S/Stn. Tanda	Additional 20 MVA, 132/11 kV Power T/F	50	132 kV S/Stn. Tanda	Additional 12.5 MVA, 132/11 kV Power T/F	50	This work is being amended on the basis of proposal received from Dy. CE/Grid Const., PSTCL, Ludhiana vide his office note No. 3177 dated 31.07.2020 and as per recommendation of CE/P&M, PSTCL, Ludhiana.

This issue with the approval of Director/Technical, PSTCL.

*Mull 9/9/20*  
Dy. CE/Planning,  
PSTCL, Patiala.

cc: - 1716/19 /P-II/ 70A Dated: 09/9/2020

- 1) Director/Technical, PSTCL, Patiala.
- 2) Chief Engineer/TS, PSTCL, Patiala.
- 3) Chief Engineer/P&M, PSTCL, Ludhiana.
- 4) Dy. CE /P&M, PSTCL, Jalandhar.