



PUNJAB STATE TRANSMISSION CORPORATION LIMITED  
Regd. Office:- PSEB Head Office, The Mall, Patiala – 147001, Punjab, India  
O/o SE/Planning, PSTCL, Patiala  
Fax/Ph:- 0175-2205502, Email:- [se-planning@pstcl.org](mailto:se-planning@pstcl.org)  
CIN-U40109PB2010SGCO33814

Amendment No: 10/2023-24

To

- 1) Dy. CE/TS (Design), PSTCL, Patiala.
- 2) Dy. CE /Grid Construction, PSTCL, Ludhiana.
- 3) Dy. CE /Civil Works, PSTCL, Patiala.
- 4) Dy. CE /TLSC, PSTCL, Patiala.

Memo No. 429/432 /P-II/70A/84

Dated: 31.07.2023


**Subject: Regarding planning of 1 No. 66 kV bay (equivalent to HTLS conductor of double current carrying capacity of 0.2 sq" conductor) at 220 kV Gaunsgarh for 66 kV S/S Treatment Plant, Jamalpur.**

The scope of work is planned as following:

Sr. No.	Name of S/Stn.	Scope of Work	Est. Cost (in Cr.)	Remarks
1.	220 kV S/S Gaunsgarh	1 no. 66 kv bay for 66 kv s/s phase-8 & Tajpur Road	-----	In view of PSPCL Amendment 14-A/2022-23 issued vide memo No. 3770 dated 12/10/2022 and 4352 dated 17/11/2022 <b>the work planned at Sr. No. 7 of PSTCL Amendment No. 25/2022-23 will be deleted.</b>
		1 No. 66 kV bay at 220 kV S/s Gaunsgarh (equivalent to HTLS conductor of double current carrying capacity of 0.2 sq" conductor) for 66 kV S/S Treatment Plant, Jamalpur on co-sharing basis between Municipal Corporation Ludhiana and PSPCL considering the work as Contributory work.	0.4841 (incl. Civil Works)  (Municipal Corp. Ldh. Share- 0.1862 + PSPCL share 0.2979)	<b>1. The work planned at Sr. No. 7 of PSTCL Amendment No. 25/2022-23 will be deleted</b> 2. This work is being planned on the basis of Amendment No. 14-A/2022-23 dtd. 12.10.22 issued by PSPCL. 3. Work is being planned as per the confirmation of space availability by ASE/TS(VII), PSTCL, Patiala & Sr. Xen/ Grid Construction, Moga vide office email dated 08.12.22 & 12.12.22 respectively. 4. Control room Extension at 220KV S/s Gounsgarh has been already planned vide amendment No. 08/22-23. 5. Estimated cost for 66 kV HTLS bay at 220 kV S/s Gaunsgarh for 66 kV S/S Treatment Plant, Jamalpur. has been considered as intimated by AEE/Grid construction, PSTCL, Ludhiana vide his office memo No. 182 dated 21.06.23 and Sr. Xen/Civil works division, PSTCL, Mohali vide memo No. 859 dated 03.07.23.


				<p>6. Expenditure of this work shall be borne on co-shared basis between by Municipal Corporation Ludhiana and PSPCL in proportion of installed capacities of their T/fs i.e. 12.5 MVA and 20 MVA respectively as per decision of WTD of PSPCL.</p> <p>7. The work to be taken in hand only after the deposit of requisite amount by firm (MC Ludhiana).</p> <p>8. The expenditure in respect of PSPCL share shall be charged to the head  <u>"Additional 220/132/66 kV line bays"</u>, Sr. No. 70 of Annexure-3 of MYT 2023-26 as per provision of Approved Capital Investment Plan for the year 2023-26.  Expenditure allocated upto control period upto March 24: <b>Rs. 11.90 Crore.</b>  Expenditure already booked via amendments till date: <b>Rs. 0.95 Crore</b>  Expenditure to be booked for this amendment: <b>Rs. 0.357 Crore (including EC &amp; IDC)</b>  Balance expenditure for the control period 23-24: <b>Rs. 10.59 Cr.</b></p> <p>9. This work shall be included in the transmission works for the FY 23-26.</p> <p>10. The work is subject to the ratification by BODs.</p>
--	--	--	--	--

This issues with the approval of Technical Committee of PSTCL comprising Director/Technical and Er. Anil Kaplush, Independent Director of PSTCL.

  
Dy. CE/Planning  
PSTCL, Patiala.

cc: - 433/39 /P-II/70A/84

Dated: 31.07.2023

  
31/7/23

- 1) Director/Technical, PSTCL, Patiala.
- 2) Chief Engineer/TS, PSTCL, Patiala.
- 3) Chief Engineer/Planning, PSPCL, Patiala.
- 4) Chief Engineer/P&M, PSTCL, Ludhiana.
- 5) Chief Engineer/P&M, PSPCL, Ludhiana.
- 6) Dy. CE/Transmission Planning, PSPCL, Patiala.
- 7) Dy. CE /P&M Circle, PSTCL, Ludhiana.