

PUNJAB STATE TRANSMISSION CORPORATION LIMITED
Regd. Office: PSEB Head Office, The Mall, Patiala – 147001, Punjab, India
O/o SE/Planning & Communication, PSTCL, PATIALA.
Fax/Ph:- 0175-2205502, Email:- se-planning@pstcl.org

CIN -U 40109 PB 2010 S G CO 33814

To

The Financial Advisor,

PSTCL. Patiala.

Memo No.

/P-1/ Dated.

Subject:- PSERC directive in the Tariff Order for MYT control period from FY-

2017-18 to FY- 2019-20.

Reference:- Your office letter to Engineer-in-Chief/TS, PSTCL, Patiala vide memo no.

32/FA/Comm./23/Vol-V, dt. 03/01/2018

Enclosed please find herewith status of PSERC Directive Sr. No. 6.3 i.e. loading status of PSTCL Transmission lines & Substations (Annexure-A).

This issues with the approval of Engineer-in-Chief/TS, PSTCL, Patiala.

SE/Planning & Communication,

Engineer-In-Chief/TS, PSTCL, Patiala - for information please.
 Chief Engineer/P&M, PSTCL, Ludhiana - for information please.

3), Sr. Xen. To Director/Tech. PSTCL, Patiala - for information please.

Addl. SE/IT, PSTCL, Patiala along with the copy of Annexure-A (both hard copy as well as soft copy mailed to your official address) for uploading on web-site please.

(ANNEXURE-'A')

S. N.	Issues	Over-Loaded lines of PSTCL	During Paddy 2016-17	Paddy 2017-18		Remarks
				Quarter 1	Quarter II	**
6.3	Loading status of PSTCL	Dhandari-PGCIL Ludhiana	116.3%	110.6%	119.5%	1) All other 220 KV as well as 132 KV lines of PSTCL Transmission System during paddy-2017 remain within their permissible thermal rating of conductor.
	Transmission lines & Substations	Lalton- PGCIL Ludhiana (Ckt-1)	104.4%	93%	101.63%	2) All 220 KV & 132 KV Substations of PSTCL during paddy-2017 remain loaded below 100%
	Substations					3) Loading of 220 KV Dhandari Kalan-PGCIL Ludhiana as well as 220 KV Lalton - PGCIL Ludhiana (Ckt-1) is expected to come down
						with replacement of existing conductor of 220 KV Lalton-Kalan-PGCIL Ludhiana (Ckt-II) with HTLS conductor which has already been planned.

