

Reply of Pre-Bid Queries against Tender Enquiry STQ-3056

S.No	Query of Bidder	Reply of PSTCL
1.	As per Clause 6.1 of IFB, Bid Security for this package is Rs. 49,00,000/- whereas according to Clause No. 13.1 of ITB, Bid Security requirement is Rs. 44,00,000/-. Please clarify this point and confirm correct value of Bid security to be submitted. Please Confirm the same	The Bid Security for this package is Rs. 49,00,000/-. Corrigendum No.1 has already been uploaded on 'eproc.punjab.gov.in' and PSTCL website regarding Amendment of Clause No. 13.1 of ITB.
2	According to Clause No. 27.5 (c), " Performance Guarantee of the Equipments: For the purpose of evaluation, no adjustment to the bid price towards performance guarantees of 500 MVA 400/220/33 KV Transformer is applicable." We understand from this clause that Loss Capitalization will not be applied during tender evaluation stage, if any bidder offers power transformer will losses lower than mentioned in technical specification.	The understanding of the bidder is confirmed that Loss Capitalization will not be applied during tender evaluation stage .
3	According to Clause 2.1 (c) of Appendix-8 ".....Further, no cost benefit shall be considered in case measured losses are less than the above maximum losses." We understand from this point that Loss Capitalization will be applied only in case Contractor supplies power transformer with losses higher (upto 15%) than maximum losses mentioned in tender specifications. In case, Contractor supplies power transformer with lower losses then he will not be given any advantage for this. Please confirm the same.	The understanding of the bidder is confirmed that no advantage will be given in case the Contractor supplies Power Transformer will lower losses .
4	Amendment in Qualifying requirement Clause pertaining to 500 MVA 400/220/33KV Autot T/f as :- " The bidder as a prime contractor must have supplied, erected, tested and commissioned 1 or more transformer bays of 400 kV or above voltage level comprising of at least Power Transformer of 200 MVA Capacity (with or without supply of Transformer) or above as on originally scheduled date of bid opening."	The Qualifying requirement Clause cannot be amended at this stage.