

Rod Earthing of 3 No. 11 KV Incomer VCB's & 4 No. NCT's of Power Transformers at 220 KV S/S Baghapurana under P&M Division, PSTCL, Moga				Annexure-1
Sr. No.	Description of Work	Qty. (In No.)	Rate to be Quoted by firm (Per Unit)	Amount
1	Rod Earthing - Providing Earthing pits (bores) upto water level 36 mtr. (75 mm dia) and laying 32 mm MS round in pits upto water level through welding, connecting them to 11 KV Incomer VCB's & NCT's with MS Flat (50*6 mm) and bringing the earth resistance upto PSTCL standard for 3 No. 11 KV Incomer VCB's & 4 No. NCT's of Power Transformers installed at 220 KV S/S Bagahapurana under P&M Division, Moga. MS Round & MS Flat are provided by PSTCL	7 No.		
GST @.....%				
Total				

The above rates are inclusive of all Taxes.

I have read all the term and conditions of the tender Enquiry & are acceptable to me and have quoted the Rate/Charges as above in accordance with stipulated Terms & Conditions.

Date:

Signature of Contractor with Stamp

Mob. No. :

Company Address

.....
.....
.....