



# PUNJAB STATE TRANSMISSION CORPORATION LIMITED

(A Punjab Govt. Undertaking)

(Regd. Office: PSEB Head Office, The Mall Patiala-147001)

Corporate Identity Number: U40109PB2010SGC033814

Office: Sr. Xen/400 kV Sub-Station, PSTCL, Sri Muktsar Sahib.

E-mail: [srxen400kvmtk@pstcl.org](mailto:srxen400kvmtk@pstcl.org)

Website: [www.pstcl.org](http://www.pstcl.org)

Contact No. 96461-04472

Enquiry No:- 11/2024-25

Dated: 24.01.2025

To

PSTCL Website

Memo No. 74

Date. 24/1/25

Subject: Inviting quotations for the purchase of Special Purpose Clamps to be used on various Transmission lines of TL S/D, Sri Muktsar Sahib under O/o Sr. Xen 400 KV S/S Sri Muktsar Sahib.

Sealed quotations for subscribed Enquiry No.11/2024-25 Dated: 24.01.2025 are invited from Registered Contractors for execution of following work .The Quotation should reach the office of the undersigned up to 12:00 Hrs on Dated: 10/02/2025. If date of opening happens to be holiday, then quotation can be submitted on following working day and same will be opened on that day . The quotations received as such will be opened in presence of committee of officers/ officials of department and representatives of contractors who want to be present.

Sr. No.	Description of Work	Tender Enquiry No.	Earnest Money (Rs)	Quantity	Last Date & Time for Submission of the tender
1	As per Annexure 'A'	TE: 11/2024-25	As applicable according to PSEB Work regulations:- 1997	Annexure 'A'	10/02/2025 till 12:00 Hrs
					Date & Time for opening of the tender
					10/02/2025 till 13:00 Hrs

#### General Terms & Conditions:-

1. Tender fee is nil
2. Conditional, Telegraphic and Incomplete Tenders will not be entertained.
3. The Tender issuing authority reserves the right to reject any or all the quotations without assigning any reason.
4. The period of work is valid till 31.03.2025 and same may be extended for another year subject to satisfactory Services.
5. The quotation should accompany with PAN Proof, GST, & registration certificate with PSTCL/PSPCL/PWD.
6. EMD@2% of tender or Min. amount 5000 /- payable by D.D in favor of Sr.Xen. P&M Division Muktsar
7. **Security Deposit:-** the earnest money deposited at the time of tender shall be converted into security deposit. The security deposited will be deducted from the running bills @5% as per prevailing rules. No interest shall be payable to contractors on amount of security deposit.
8. Any enquiry regarding this can be made on any working day at office of undersigned.
9. All the statutory rules and regulations such as EPF Act, ESI Act, Labour Rules and regulations, Wages Regulations Etc, As per department of labour, Govt of Punjab shall be followed by the contractor. Contractor will be fully responsible for any kind of penalty levied by the central or any other agency for not following the statutory rules and regulations.
10. The undersigned reserves the right to cancel this NIT without giving any reasons.
11. Please do not forget to super scribe the envelop (s) with the name of tender and due date of opening of tender.
12. Income Tax, Labour Cess shall be deducted at source as per prevailing rules and rates and as per provisions of Goods & Service Tax (GST) Law.
13. Payment for the work done will be made by Sr.Xen/P&M Division, PSTCL, Sri Muktsar Sahib.
14. The quantity of work may be increased or decreased.


  
Sr. Xen,  
400 kV s/s, PSTCL  
Sri Muktsar Sahib.

Endst. No.: 75/77

Dated: 24/1/25

Copy of the above is forwarded to the following for information and necessary action.

1. SE, P&M Circle, PSTCL,
2. Addl SE, P&M division Sri Muktsar sahib.
3. AO/Audit, PSTCL, Bathinda

  
Sr. Xen,  
400 kV s/s, PSTCL  
Sri Muktsar Sahib.

# Schedule of Prices (Annex.-A)


TE. No. 11/2024-25

Sr no	Description of Material/Item	Qty (no.)	Rates Quoted Per item without GST (Rs)	GST % Extra	Total Amount With GST
1	Special Purpose Clamp suitable for 0.4 sq Inch ACSR Zebra conductor for fitting on 48 MM to 55 MM ROD (Endcone, AI Made) with U Bolts being provided for proper tightening used for jumpering work on 220 kv Transmission lines.	30			
2	Special Purpose Clamp suitable for 0.5 sq Inch ACSR Moose conductor for fitting on 48 MM to 55 MM ROD (Endcone, AI Made) with U Bolts being provided for proper tightening used for jumpering work on 400 kv Transmission lines.	15			

  
Sr. Xen  
400 kv S/S, PSTCL  
Sri Muktsar Sahib

**TECHNICAL SPECIFICATIONS:-**

1. Clamp shall be suitable for fitting on 48MM to 55MM ROD (Endcone, Al Made) with U Bolts being provided for proper tightening used for jumpering work on 220 kv Transmission lines.
2. Current Carrying Capacity: 2500 Ampere or more.
3. Duly pressed Al thimble shall be provided one side flat for connecting with terminal pad connector of clamp & one side for jumper fitting.
4. Samples may be seen in the O/O AEE/TL/SD PSTCL, Sri Muktsar Sahib in case of any clarification required.

  
Sr. xcr  
400 kv SIS, PSTCL  
Sri Muktsar Sahib