



PUNJAB STATE TRANSMISSION CORPORATION LIMITED
Regd. Office: - PSEB Head Office, The Mall, Patiala – 147001, Punjab, India
O/o SE/Planning, PSTCL, Patiala.
Fax/Ph: - 0175-2205502, Email: - se-planning@pstcl.org
CIN - U40109PB20105GCO33814

To,

Amendment No: **13**/2024-25

1. Dy. CE/TLSC Circle, PSTCL, Patiala.
2. Dy. CE/TS(Design), PSTCL, Patiala.

Memo No. **480/81** P-I/427

Dated: **05/8/2024**

Subject: Regarding Erection of 1 no new tower under 220kV GHTP Lehra Mohabbat-Maur/Dhanaula D/C line for maintaining ground clearance of conductor of tower no 3 & 4.

The scope of work is planned as below: -

Sr. No.	Name of Line	Scope of work	Estimated cost of work (in Crore)	Remarks
1	220kV GHTP Lehra Mohabbat-Maur/Dhanaula D/C line	Erection of 1 no. new tower between tower no 3 & 4 of 220kV GHTP Lehra Mohabbat-Maur/Dhanaula line near GHTP, lehra mohabbat for maintaining ground clearance of conductors.	0.23	<ol style="list-style-type: none">1. This work is being planned as per the request received from ASE/P&M, division, PSTCL, Bathinda vide letter no. 3061 dated 18.07.2024.2. Estimated cost has been considered as intimated by ASE/TLSC, Division, Patiala vide email dated 31.07.2024.3. The work shall be included in the Transmission works for the FY 2023-26.4. Expenditure for this Work shall be booked to the head "Unforeseen emergency works" Sr. no. 71 of Annexure-3 of MYT 2023-2026.

				5. Total estimated cost after including EC @ 15 % and IDC @ 9.5 % (FY 2024-25) shall be Rs. 0.29 Cr.
				6. This work is subject to ratification by BODs of PSTCL.
		Total	0.23	
		Total cost including EC & IDC	0.29	

This issues with the approval of Director/Technical, PSTCL.

Sr. XEN/Planning-I,
PSTCL, Patiala.

cc: - 482/88

Dated: 05/8/2024

1. Director/Technical, PSTCL, Patiala.
2. EIC/TS, PSTCL, Patiala.
3. EIC/P&M, PSTCL, Ludhiana.
4. Chief Engineer/Planning, PSPCL, Patiala.
5. Dy. Chief Engineer/P&M, PSTCL, Bathinda.
6. Dy. Chief Engineer/Grid Construction, PSTCL, Ludhiana.
7. Dy. Chief Engineer/Civil works, PSTCL, Patiala.