



PUNJAB STATE TRANSMISSION CORPORATION LIMITED

Regd. Office:- PSEB Head Office, The Mall, Patiala – 147001, Punjab, India

O/o SE/Planning, PSTCL, Patiala

Fax/Ph:- 0175-2205502, Email:- se-planning@pstcl.org

CIN-U40109PB2010SGCO33814

To

Amendment No: 27/2024-25

- 1) Dy. CE/TS (Design), PSTCL, Patiala.
- 2) Dy. CE/Civil Works, PSTCL, Patiala.
- 3) Dy. CE/TLSC, PSTCL, Patiala.
- 4) Dy. CE/Grid Construction, PSTCL, Ludhiana.

Memo No. 685/28

P-1/373-A Dated: 20.12.2024


Subject: - Revised Feasibility Clearance for a new connection of Northern Railway TRD Branch, DRM office, Ambala Cantt. Of load of 4500 kW/ 5000kVA. (App no. 5904) at Bhawal Bassi instead of Panjkosi.

Ref.: This office Amendment No. 29/2023-24 issued vide memo no. 666/69/P-1/373-A dated 27.12.2023.

Point no. 7- "This work will be considered as Deposit work" is hereby added in the Remarks column of Amendment no. 29/2023-24 issued vide memo no. 666/69/P-1/373-A dated 27.12.2023.

All other provisions/scope of work in the amendment shall remain unchanged.

This issues with the approval of Director/Technical, PSTCL.


Sr. XEN/Planning-1,
PSTCL, Patiala.

CC: - 689/94

Dated: 20.12.2024

- 1) Director/Technical, PSTCL, Patiala.
- 2) Engineer-in-Chief/Commercial, PSPCL, Patiala.
- 3) Engineer-in-Chief/TS, PSTCL, Patiala.
- 4) Chief Engineer/Planning, PSPCL, Patiala.
- 5) Dy. Chief Engineer/P&M, PSTCL, Bathinda.
- 6) Dy. CE/Distribution, PSPCL, Shri Muktsar Sahib.



PUNJAB STATE TRANSMISSION CORPORATION LIMITED

Regd. Office:- PSEB Head Office, The Mall, Patiala – 147001, Punjab, India

O/o SE/Planning, PSTCL, Patiala

Fax/Ph:- 0175-2205502, Email:- se-planning@pstcl.org

CIN-U40109PB20105GCO33814

To,

Amendment No: 29/2023-24

- 1) Dy. CE/TS (Design), PSTCL, Patiala.
- 2) Dy. CE/Civil Works, PSTCL, Patiala.
- 3) Dy. CE/TLSC, PSTCL, Patiala.
- 4) Dy. CE/Grid Construction, PSTCL, Ludhiana.

Memo No. 666/69 P-1/373A Dated: 27/12/2023

Subject: - Revised Feasibility Clearance for a new connection of Northern Railway TRD Branch, DRM office, Ambala Cantt. Of load of 4500 kW/ 5000kVA. (App no. 5904) at Bhawal Bassi instead of Panjkosi.

The revised scope of work is planned as follows: -

Sr. No.	GSS	TSS	Scope of Work	Est. Cost (Rs.)	Remarks
1.	220kV Switching Station at Bhawal Bassi	220 kV S/S Bhawal Bassi	1)Erection of new 220kV Switching Station at Bhawal Bassi with LILO of 220kV Abohar-Malout line with ACSR 0.4 sq" D/C of 4 km(approx.) 2)Erection of new 220kV line with ACSR 0.4sq" line length 0.5km (approx.) from 220kV Switching Station to RTSS Bhawal Bassi S/C on	Rs. 500 lacs (approx.) (Grid Const.) + Rs.618.54lacs (TLSC Divn.) + Rs. 400 lacs (Civil works) + Rs.40.22 lacs (OPGW cost)	1. This work is being revised in view of Revised FCC decision issued by ASE /Sales-4 O/o EIC/ Commercial PSPCL, Patiala vide memo no. 1827/SWS/App No. 5904 dated 17.10.2023 (copy enclosed). 2. Estimated cost has been considered as intimated by ASE/Grid Const. Circle, PSTCL, Moga vide memo no. 2231 dated 21.07.2023, Sr. XEN/TLSC Division, PSTCL, Patiala vide endst. No. 2296 dated 29.11.2023, Sr.XEN/Civil works Jalandhar, vide email dated 15.12.2023 & AEE/ CO & C, PSTCL, Muktsar Sahib vide email dated 19.12.2023. 3. LILO of 220kV Malout-Abohar line at Bhawal Bassi along with construction of

			D/C.		<p>switching Station shall be carried out exclusively for Railways and Railway will bear the entire cost of Switching Station, line bays, Switch house building and LILO lines etc.</p> <p>4. The work will be started after deposit of the amount by PSPCL/ Railways to PSTCL.</p> <p>5. This work is subject to ratification by Technical Committee of PSTCL and subsequently by BODs of PSTCL.</p> <p>6. This Amendment shall supersede the Amendment no. 30/2022-23 dated 31.08.2022.</p>
			Total	1558.76 lacs	

This issues with the approval of Director/Technical please.

Mal

**Sr. XEN/Planning-1,
PSTCL, Patiala.**

cc: - 670/75

Dated: 27/12/2023

- 1) Director/Technical, PSTCL, Patiala.
- 2) EIC, Commercial, PSPCL, Patiala.
- 3) Chief Engineer/TS, PSTCL, Patiala.
- 4) Chief Engineer/Planning, PSPCL, Patiala.
- 5) Dy. Chief Engineer/P&M, PSTCL, Bathinda.
- 6) Dy. CE/Distribution, PSPCL, Shri Mukatsar Sahib.