



PUNJAB STATE TRANSMISSION
CORPORATION LIMITED

PUNJAB STATE TRANSMISSION CORPORATION LIMITED

Regd. Office: - PSEB Head Office, The Mall, Patiala – 147001, Punjab, India

O/o SE/Planning, PSTCL, Patiala.

Fax/Ph: - 0175-2205502, Email: - se-planning@pstcl.org

CIN - U40109PB2010SGCO33814

To,

Amendment No 28/2024-25

- 1) Dy. CE/Grid Construction, PSTCL, Ludhiana.
- 2) Dy. CE/TS (Design), PSTCL, Patiala.
- 3) Dy. CE/TLSC, PSTCL, Patiala.
- 4) Dy. CE/Civil Works, PSTCL, Patiala.

Memo No. 07/10 P1-208

Dated: 15-01-2025

Subject: Regarding upgradation of 66kV S/Stn. Giaspura to 220kV level

Reference: This office Amendment No. 18/2024-25 issued vide memo no. 548/51/P1-208 dated 29.08.2024

In the context of the subject cited, it is intimated that the amendment no. 18/2024-25 has been **deferred** by the BODs in their 87th meeting held on 04.12.2024 against the Agenda Note No. 92/P-II/224 dated 23.10.2024 (copy of BOD decision enclosed).

This is for your kind information please.


Sr. XEN/Planning-1,
PSTCL, Patiala.

CC: -


15.01.2025

Dated: 15-01-25

- 1) Director/Technical, PSTCL, Patiala.
- 2) Chief Engineer/TS, PSTCL, Patiala.
- 3) Chief Engineer/P&M, PSTCL, Ludhiana.
- 4) Chief Engineer/Planning, PSPCL, Patiala.
- 5) Dy. Chief Engineer/P&M, PSTCL, Ludhiana.



PUNJAB STATE TRANSMISSION CORPORATION LIMITED

Regd. Office: - PSEB Head Office, The Mall, Patiala – 147001, Punjab, India

O/o SE/Planning, PSTCL, Patiala.

Fax/Ph: - 0175-2205502, Email: - se-planning@pstcl.org

CIN - U40109PB2010SGCO33814

Amendment No: 8/2024-25

To,

- 1) Dy. CE/Grid Construction, PSTCL, Ludhiana.
- 2) Dy. CE/TS (Design), PSTCL, Patiala.
- 3) Dy. CE/TLSC, PSTCL, Patiala.
- 4) Dy. CE/Civil Works, PSTCL, Patiala.

Memo No. *548/SI/PI-208* Dated: *29.08.2024*


Subject: Regarding the scope of upgradation of 66kV S/Stn. Giaspura to 220kV level

The scope of work is planned as below:

S. No.	Name of S/Stn.	Scope of work	Estimated cost (in Crores)	Remarks
1.	220 kV Giaspura (Upgradation from 66kV with hybrid setup i.e. 220 kV portion GIS and 66 kV portion AIS) including SAS	Upgradation of 66kV Giaspura to 220kV with installation of 2X160 MVA, 220/66 kV transformers (including 220 KV GIS 4 Nos. line bays, 3 No. T/F bays and 4 No. Tie bays, 22 nos. 66 kV AIS bays (6no. for power T/F, 2 nos. interconnecting bays, 2 no. for bus coupler, 12 nos. line bays) (Including all civil works of GIS building, control room and administrative room etc.)	140.45	1. The work of replacement of existing ACSR conductor of 220 KV Jamalpur – Dhandari Kalan line with equivalent HTLS conductor (on same towers) having capacity of at least 1200 A has been included in the scope of upgradation of 66 kV Giaspura to 220 kV level because of the high loading of 220 KV Jamalpur – Dhandari Kalan line under normal conditions. 2. Estimated cost has been considered as received from O/o TS-Design/Cell-1 vide email dated 20.08.2024.

	LILO of both circuits of 400 kV Ludhiana – 220 kV S/stn. Dhandari Kalan line at 220 kV S/stn Giaspura (Proposed) on Multi-circuit Monopoles with ACSR Zebra conductor. Length of LILO portion = 4 km M/C (approx.) i.e. 16 circuit km (approx.)	42.707	3. This work shall be booked to head: "New 220kV Giaspura including SAS of Rs. 1 cr", Sr. No. 47 of Table C: "Spill over of New works planned for 2 nd Control Period from FY 2020-21 to 2022-23" of Annexure-1 as per approved Capital Investment Plan for MYT control period 2023-26.
	Replacement of existing ACSR conductor of 220 KV Jamalpur – Dhandari Kalan line with equivalent HTLS conductor (on same towers) having capacity of at least 1200 A (3.5 km approx.)	1.785	4. This work is subject to ratification by BODs of PSTCL & subsequent approval of PSERC.
	Total	184.942	
	Total estimated cost including EC @ 15% and IDC @ 9.5%	232.89	

This issues with the approval of the Director/Technical of PSTCL.


Sr. XEN/Planning-1,
PSTCL, Patiala.

CC: -

552/56

Dated: 29.08.2024

- 1) Director/Technical, PSTCL, Patiala.
- 2) Chief Engineer/TS, PSTCL, Patiala.
- 3) Chief Engineer/P&M, PSTCL, Ludhiana.
- 4) Chief Engineer/Planning, PSPCL, Patiala.
- 5) Dy. Chief Engineer/P&M, PSTCL, Ludhiana.



PUNJAB STATE TRANSMISSION CORPORATION LIMITED

(Regd. Office: PSEB Head Office, The Mall, Patiala-147001)

Corporate Identity Number: U40109PB2010SGC033814

www.pstcl.org (O/o Company Secretary) E-mail: comp-secy@pstcl.org

Tel. No. 0175-2970047

Dy. C&D
Dy. DE
Sr. Xen
AO/TS
Sr. PS

1297
24/12/2024

Subject: EIC/TS Agenda Note No. 92/P-II/224 dated 23.10.2024- Grant of administrative approval for inclusion of works in the Capital Investment plan of PSTCL for MYT Control period from FY 2023-2024 to FY 2025-2026.

The decision taken by Board of Directors in its 87th Meeting held on 04.12.2024 at Kothi No. 33, PSPCL Guest House cum Transit Camp, Sector-10-A, Chandigarh, on the above subject is as under:-

"Board perused the agenda put up by EIC/TS and considered the proposal in para 2 of the agenda. Board after due consideration approved the Categories A (Table-1), B (Table-3), and C (Table-3) as proposed in Para-2 of the agenda and deferred the decision on Category D (Table-5).

Thereafter, Board passed the following resolution:

"RESOLVED THAT Transmission works planned vide amendment no. 12/2024-25 to 14/2024-25, 16/2024-25 and 19/2024-25 to 21/2024-25 be and are hereby approved as Emergent Works and deferred the decision on amendment no. 18/2024-25. The approval of PSERC may be sought as proposed in the agenda."

This is for information and necessary action under due intimation to this office please.

Jasjit Pandey
Company Secretary
PSTCL, Patiala.

To

Engineer-in-Chief/TS,
PSTCL, Patiala.

U.O. No. 2568 /BOD/87.16 /PSTCL

Dated: 23-12-24

Sr. PS
AJP
31
my
31/12/24
AJP
SK
PK
MP